

Manufacturer's declaration of compliance for standards and quality

We declare that the following product: **Mechanical lock case ABLOY®4232**

has been successfully tested to: **EN 12209 : 2003 – Building hardware – Locks and latches –
Requirements and test methods**

with the following classification

a	b	c	d	e	f	g	h	i	j	k
3	C	7	0	0	F	4	B/C	C	-	0

Box	Classification	Grade or category
a	Category of use	high chance of misuse
b	Durability	number of test cycles 50 000
c	Door mass and closing force	up to 100 kg door mass
d	Fire resistance	no requirement
e	Safety	no requirement
f	Corrosion resistance and temp.	high corrosion resistance, temperature from -20 to + 80 °C
g	Security	side load 7 kN, disengaging load 2 kN, to be used with box locking plate
h	Field of door application	mortise, hinged and sliding, forend not supported
i	Type of key operation and locking	cylinder lock, manually locking with intermediate locking
j	Spindle operation	not applicable
k	Key identification	no requirement

and the following optional requirements:

when used for the following purpose:

Evidence of standards compliance:

- ☒ Type testing by Manufacturer
- ☐ Type testing by Manufacturer to EN 45001
- ☐ Type testing by Independent recognised laboratory Lab.ref.
- ☐ Regular audit testing by Manufacturer
- ☐ Regular audit testing by Manufacturer to EN 45001
- ☐ Regular audit testing by Independent recognised laboratory Lab.ref:
- ☐ Other (specify):


Evidence of quality compliance:

- ☐ Manufacturer's own quality system
- ☐ Manufacturer's quality system to EN 9002
- ☐ Manufacturer's quality system to EN 9001
- ☐ Manufacturer's quality system to EN 9002 with Independent quality assessment (3rd Party ref):
- ☒ Manufacturer's quality system to EN 9001 with Independent quality assessment (3rd Party ref): **Det Norske Veritas**
- ☐ Other (specify):

Evidence of marking compliance:

- ☒ None
- ☐ CE-marking
- ☐ Quality label (specify):
- ☐ Other (specify):

Signature:


Jouni Haapaniemi

Date: April 25, 2008

Position:

Product Manager

Company:

Björkboda Lås Oy Ab / Konttorintie, 25860 Björkboda

