

**Declaration of Performance No. DOP1011**  
27.6.2013

**MANUFACTURER:**

**Abloy Oy**  
**Joensuu factory**  
Wahlforsinkatu 20  
FI-80100 Joensuu  
FINLAND

System or systems of assessment and verification of constancy of performance of the construction product:  
**AVCP 1**

**NOTIFIED PRODUCT CERTIFICATION BODY:**

**DNV**  
**Business Assurance**  
ID No: 1162  
Hemvärnsgatan 9  
S17106 Solna  
SWEDEN

Notified product certification body performed the determination of the product type on the basis of type testing (including sampling), initial inspection of the manufacturing plant and of the factory production control and continuous surveillance, assessment and evaluation of factory production control and issued the certificate of constancy of performance of the product.

No. **1162-CPD-0252**

**PRODUCT AND DESCRIPTION**

**Type:**  
**ABLOY DC334**

**Description:**  
Controlled door closing devices (door closers)

**Intended use:**  
On fire and smoke compartmentation doors (to fulfil the self-closing requirements of such doors)


**Arm:**  
projecting arm, size EN1-4

Classification			EN1154:1996/ A1:2002 + AC:2006  Building hardware. Controlled door closing devices.
4.2 Category of use	4	for closing doors from 180°	
4.3 Number of test cycles	8	500 000 cycles	
4.4 Test door mass	1-4	power size adjustable	
4.5 Fire behaviour	1	Suitable for use on fire doors	
4.6 Safety	1	only grade 1 is identified	
4.7 Corrosion resistance	3	high resistance (96h)	

Brand	Type
ABLOY	DC334
JPM	FP3341

Joensuu 27.6.2013

On behalf of Abloy Oy, Door Control

  
signature

Antti Piitulainen  
Vice President