

Declaration of Performance No. DOP1024

27.6.2013

MANUFACTURER:

Abloy Oy
Joensuu factory
 Wahlforssinkatu 20
 FI-80100 Joensuu
 FINLAND

System or systems of assessment and verification of constancy of performance of the construction product:
AVCP 1

NOTIFIED PRODUCT CERTIFICATION BODY:

MPA NRW
Materialprüfungsamt
Nordrhein-Westfalen
 ID No: 0432
 Marsbruchstraße 186
 44287 Dortmund-Aplerbeck
 GERMANY

Notified product certification body performed the determination of the product type on the basis of type testing (including sampling), initial inspection of the manufacturing plant and of the factory production control and continuous surveillance, assessment and evaluation of factory production control and issued the certificate of constancy of performance of the product.

EN1158
 No. **0432-CPD-0049**

EN1155
 No. **0432-CPD-0050**

PRODUCT AND DESCRIPTION

Type:
ABLOY FD480, FD481, FD482, FD484

Description:
 Electrically powered hold-open device and door coordinator

Intended use:
 On fire and smoke compartmentation doors
 (to fulfil the self-closing requirements of such doors)

Classification			EN1155:1997 + A1:2002 Electrically powered hold-open devices
4.2 Category of use	3	for doors for use by the public,	
4.3 Number of test cycles	8	500 000 cycles	
4.4 Test door mass	3-6	power size adjustable	
4.5 Fire behaviour	1	suitable for use on fire doors	
4.6 Safety	1	only grade 1 is identified	
4.7 Corrosion resistance	0	NPD	

Classification			EN1158:1997 + A1:2002 Door coordinator devices
4.2 Category of use	3	for doors for use by the public,	
4.3 Number of test cycles	8	500 000 cycles	
4.4 Test door mass	3-6	power size adjustable	
4.5 Fire behaviour	1	suitable for use on fire doors	
4.6 Safety	1	only grade 1 is identified	
4.7 Corrosion resistance	0	NPD	

Brand	Type
ABLOY	FD480, FD481, FD482, FD484
ASSA ABLOY	G880, G881, G882, G884
TESA	GDEXM, GD2XSC, GD2XEM1, GD2XEM2

Joensuu 27.6.2013

On behalf of Abloy Oy, Door Control


 signature

Antti Piitulainen
 Vice President