

Declaration of Performance No. DOP1005

27.6.2013

MANUFACTURER:

Abloy Oy
Joensuu factory
 Wahlforssinkatu 20
 FI-80100 Joensuu
 FINLAND

System or systems of
 assessment and verification
 of constancy of
 performance of the
 construction product:
AVCP 1

NOTIFIED PRODUCT CERTIFICATION BODY:

MPA NRW
Materialprüfungsamt
Nordrhein-Westfalen
 ID No: 0432
 Marsbruchstraße 186
 44287 Dortmund-Aplerbeck
 GERMANY

Notified product certification
 body performed the
 determination of the
 product type on the basis of
 type testing (including
 sampling), initial inspection
 of the manufacturing plant
 and of the factory
 production control and
 continuous surveillance,
 assessment and evaluation
 of factory production control
 and issued the certificate of
 constancy of performance
 of the product.

No. **0432-CPD-0047**

PRODUCT AND DESCRIPTION

Type:
ABLOY DC840

Description:
 Controlled door closing devices (door closers)

Intended use:
 On fire and smoke compartmentation doors
 (to fulfil the self-closing requirements of such doors)


Arm:
 concealed slide channel, size EN1-4

Classification			EN1154:1996/ A1:2002 Building hardware. Controlled door closing devices.
4.2 Category of use	3	for closing doors from at least 105° (<120°)	
4.3 Number of test cycles	8	500 000 cycles	
4.4 Test door mass	1-4	power size adjustable	
4.5 Fire behaviour	1	Suitable for use on fire doors	
4.6 Safety	1	only grade 1 is identified	
4.7 Corrosion resistance	3	high resistance (96h)	

Brand	Type
ABLOY	DC840
ASSA ABLOY	DC840
TESA	TEX14
JPM	FP8400

Joensuu 27.6.2013

On behalf of Abloy Oy, Door Control


 signature

Antti Piitulainen
 Vice President