

# Declaration of Performance No. DOP1023

27.6.2013

## MANUFACTURER:

**Abloy Oy**  
**Joensuu factory**  
 Wahlforssinkatu 20  
 FI-80100 Joensuu  
 FINLAND

System or systems of assessment and verification of constancy of performance of the construction product:  
**AVCP 1**

## NOTIFIED PRODUCT CERTIFICATION BODY:

**MPA NRW**  
**Materialprüfungsamt**  
**Nordrhein-Westfalen**  
 ID No: 0432  
 Marsbruchstraße 186  
 44287 Dortmund-Aplerbeck  
 GERMANY

Notified product certification body performed the determination of the product type on the basis of type testing (including sampling), initial inspection of the manufacturing plant and of the factory production control and continuous surveillance, assessment and evaluation of factory production control and issued the certificate of constancy of performance of the product.

**EN1158**  
 No. **0432-CPD-0049**

**EN1155**  
 No. **0432-CPD-0050**

## PRODUCT AND DESCRIPTION

**Type:**  
**ABLOY FD460, FD461, FD462, FD464**

**Description:**  
 Electrically powered hold-open device and door coordinator

**Intended use:**  
 On fire and smoke compartmentation doors  
 (to fulfil the self-closing requirements of such doors)

Classification			EN1155:1997 + A1:2002  Electrically powered hold-open devices
4.2 Category of use	3	for doors for use by the public,	
4.3 Number of test cycles	8	500 000 cycles	
4.4 Test door mass	3-6	power size adjustable	
4.5 Fire behaviour	1	suitable for use on fire doors	
4.6 Safety	1	only grade 1 is identified	
4.7 Corrosion resistance	3	high resistance (96h)	

Classification			EN1158:1997 + A1:2002  Door coordinator devices
4.2 Category of use	3	for doors for use by the public,	
4.3 Number of test cycles	8	500 000 cycles	
4.4 Test door mass	3-6	power size adjustable	
4.5 Fire behaviour	1	suitable for use on fire doors	
4.6 Safety	1	only grade 1 is identified	
4.7 Corrosion resistance	3	high resistance (96h)	

Brand	Type
ABLOY	FD460, FD461, FD462, FD464
ASSA ABLOY	G460, G461, G462, G464
TESA	GD15EM, GD25SC, GD26EM1, GD25EM2

Joensuu 27.6.2013

On behalf of Abloy Oy, Door Control

  
 signature

Antti Piitulainen  
 Vice President