

Declaration of Performance No. DOP1013
27.6.2013

MANUFACTURER:

Abloy Oy
Joensuu factory
Wahlforssinkatu 20
FI-80100 Joensuu
FINLAND

System or systems of
assessment and verification
of constancy of
performance of the
construction product:
AVCP 1

**NOTIFIED PRODUCT
CERTIFICATION BODY:**

MPA NRW
Materialprüfungsamt
Nordrhein-Westfalen
ID No: 0432
Marsbruchstraße 186
44287 Dortmund-Aplerbeck
GERMANY

Notified product certification
body performed the
determination of the
product type on the basis of
type testing (including
sampling), initial inspection
of the manufacturing plant
and of the factory
production control and
continuous surveillance,
assessment and evaluation
of factory production control
and issued the certificate of
constancy of performance
of the product.

No. **0432-CPD-0124**

PRODUCT AND DESCRIPTION

Type:
ABLOY FD440

Description:
Door closer with integrated hold open or free-swing function

Intended use:
On fire and smoke compartmentation doors
(to fulfil the self-closing requirements of such doors)

Arm:
projecting arm
for hold open DC199, size EN3-6
for free-swing FD499, size EN3-6


slide channel
for hold open DC194, size EN3-4
for free-swing FD494, size EN3-4

Classification			EN1155:1997 + A1:2002 Electrically powered hold- open devices
4.2 Category of use	3	for doors for use by the public	
4.3 Number of test cycles	8	500 000 cycles	
4.4 Test door mass	3-6	power size adjustable	
4.5 Fire behaviour	3-4	suitable for use on fire doors	
4.6 Safety	1	only grade 1 is identified	
4.7 Corrosion resistance	1	only grade 1 is identified	
	3	high resistance (96h)	

Brand	Type
ABLOY	FD440
ASSA ABLOY	DC640
TESA	BLE3000/GLE300

Joensuu 27.6.2013

On behalf of Abloy Oy, Door Control


signature

Antti Piitulainen
Vice President